

Date 11/20/79Permit No. 79-74

TOWN OF ACTON

APPLICATION FOR PERMIT TO CONSTRUCT WITHIN A PUBLIC WAY

This application must be submitted not less than five (5) days prior to any Construction within a public way.

Notice 24 hours in advance of any construction must be given to the Town Engineer.

1. Permittee: COOPERATION BETH ELCHIM Address: PO BOX 142 ACTON
2. Location of Proposed Construction: HENNESSEY DR
3. Purpose of Construction: TOP WATER MAIN
4. Length of Cut: 25'
5. Width of Cut: 3'
6. Width of Existing Pavement: 20'
7. Type of Existing Roadway Surface: 24' Type of Curb: BERM BIT
8. Type of Existing Sidewalk Surface: Type of Shoulder:
9. Date of Street Opening: From 11/20/79 To 10/25/79

I, the undersigned, hereby declare that I have read and agree to the Town of Acton Specifications for Regulating Construction with Public Ways dated February 4, 1969. I have deposited the required bond with the Town of Acton, and I covenant and agree that the Town may deduct from this amount the cost of repairs to the road surface, curbs, shoulders, walls or other features within the right-of-way including replacing bounds if not completed by me to the satisfaction of the Town Engineer within the specified time.

Witness my hand and seal,

Signature of Applicant [Signature]

Special Instructions:

The Town Engineer must be notified when work begins. The backfill shall be selected gravel compacted in 6" lifts. A temporary hot top patch shall be installed to the satisfaction of the Town Engineer for the winter. The permanent patch will be placed in the spring - see enclosed specifications.

12-13-79 D.A. D.H. M.K.

- 1) WATER SERVICE IN ROAD NOT PATCHED - NEEDS TEMP. PATCH AS PER ABOVE.

INSP. 5-13-80 D.A. , D.H.

- 1) H₂O SERVICE CUT NOT PATCHED (C.C. BLOOM COMM.)

INSP 5-5-81 ROAD REPAVED O.K

Permit Issued: Date NOV. 29, 1979

By: [Signature]

Application Denied: Date

By:

Work Inspected and Approved: Date MAY 5, 1981

By: [Signature]

Fee \$5.00

ASSIST. TOWN ENGR.

(over)